

Clean Agent Extinguishing System Units

[See General Information for Clean Agent Extinguishing System Units](#)

KIDDE FIRE PROTECTION

EX5054

THAME PARK RD

THAME

OXFORDSHIRE

OX9 ERT ENGLAND, UNITED KINGDOM

PRE-ENGINEERED UNITS Models e7763-101, -102, -103, -104, -105, -106, -107, -108, -109, -110, -111, -112, and -113, GX-20 Clean Agent Extinguishing System Units, stored pressure type, having nominal charging capacities of 5, 8, 16, 28, 51, 81, 81, 142, 142, 243, 243, 368 and 368 L of FM-200 Clean Agent, respectively. The units are super pressurized to 25 bar with operating temperatures of -0 C to +54 C. The units are designed for total flooding protection against Class A surface burning, Class B flammable liquid and Class C fires occurring within an enclosure.

These systems are intended to be designed and installed in accordance with the Listee's Design, Installation, Operation and Maintenance Manual, P/N 59812-422, Issue C, dated November 2004. These installations require the use of the Listee's Flow Calculation Software, Version GX3.03 (reference Software User's Manual P/N E9832-014, Issue B, dated November 2004). Copies are available from the Listee.

Last Updated on 2005-03-15

This page and all contents are Copyright © 2005 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2005 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

